



22th December 2010

Latchways Fall Arrest Systems
Latchways plc
Hopton Park
Devizes
Wiltshire
SN10 2JP
FAO Mr Jonathan Seymour

Ref CFP on s/s VMZINC

Dear Mr Seymour,

Re: Validity of our VMZINC product guarantee

We refer to the results of the tests of the Mansafe CFP with 0.7mm QUARTZ-ZINC PLUS standing seam 600mm wide panels on an Admaster insulated panel which your company performed on December 11, 2009, a copy of which is attached hereto.

Based on your results we understand that the Mansafe Constant Force post system can be installed on VM Zinc roofs in restraint applications only

We confirm that the attachment of the Mansafe Constant Force Post fall protection system to the above mentioned VMZINC roof panel will not invalidate the VMZINC product guarantee to our customers as defined in our General Conditions of Sale (the “**VMZINC Guarantee**”).

For the avoidance of doubt this VMZINC Guarantee includes neither compliance with the norm BS EN 795 itself nor any specifications concerning the Mansafe CFP, which remain the entire responsibility of Latchways.

Should you have any queries on the above or require further information please do not hesitate to contact us.

Yours sincerely

Jonathan Lowy
Technical Manager

Emission Date: 22/12/10
Revision Date:
Validated By J Lowy
VMZINC

Internal Document £
External Document T
Tel: 01992 822288
www.vmzinc.co.uk

